

(7)

Office of Joint Director
Public Health Institute,
Bengaluru - 560001

Report of Bacteriological analysis of Water Sample

Date: 21/02/2026.

Medical Officer Namma Clinic J.P. Nagar Uphe. BBMP.	Opinion							
	Sample No	Source & Particulars of Water Sample	M.P.N Count	Plate Count	D.C. Test	S.P.P	N.S.P.P	N.S.P.P & FC
Note: M.P.N. Count: Most Potable number of Bacteria Per 100ml of Water D.C Test: Differential Coliform test Plate Count: Plate Count per ml of sample SPP: Water is satisfactory for Potable purpose NSPP: Water is not satisfactory for Drinking purpose NSPP & FC: Water is not satisfactory for Drinking purpose and E. Coli found	4970	Samved School. No. 13, 17th Cross, 20th main. J.P. Nagar. R.O.	NIL	—	—	SPP	—	—

For Joint Director (Labs)
PUBLIC HEALTH INSTITUTE,
Bengaluru

SAMVED SCHOOL

Sundhya Soddhanta
Secretary

SAMVED SCHOOL

Principal

(PTO)

Advice:

1. Sample

Need effective chlorination before

2. Sample

Need to avoid possible source of faecal contamination and effective chlorination before use for the purpose of Chlorination. Refer the Annexure enclosed.

STANDARD FOR THE DRINKING WATER

		Presumptive Coliform Count Per 100 ml	E Coli Count Per 100 ml
CLASS 1	Excellent	0	0
CLASS 2	Satisfactory	1-3	0
CLASS 3	Suspicious	4-10	0
CLASS 4	Unsatisfactory	Greater than 10	0.1 or More

SAMVED SCHOOL

Sandhya Siddharth
Secretary

SAMVED SCHOOL

Principal